



*Borough of Sea Bright
Bureau of Fire Safety
1167 Ocean Ave.
Sea Bright, N.J. 07760
(732) 842-0099 ext. 30
(732) 741-3116 fax*

Thomas K. Haege
Fire Marshal

PLAN REVIEW AND COMMENTS

Memo To: Candace Mitchell

Memo From: Tom Haege

Subject: 1080 Ocean Ave., The Break at Sea Bright

Date: 10/06/2020

1. The proposed building contains a fire sprinkler system. A vehicle access area may need to be designated and striped "fire lane", depending on the location of the Fire Department Connection. The area shown on plans as 5-minute parking may possibly be utilized as the access area.

Tom Haege
Fire Official